



NOTES:

1. ALL MATERIALS AND INSTALLATION PROCEDURES WILL CONFORM TO HWD SPECIFICATIONS.
2. OWNER MUST PROVIDE A CLEAN, DRY ACCESSIBLE AND WARM (CONTINUALLY ABOVE 45°F) LOCATION FOR THE WATER METER.
3. SERVICE LINE FROM STREET, SIZE & MATERIALS TO BE APPROVED BY HWD. ONLY TYPE "K" COPPER TUBING OR CLASS 52 DUCTILE IRON PIPE ARE ACCEPTABLE FOR SERVICE LINES. SAND TO BE USED FOR BACK FILL FOR A MINIMUM OF 6" ABOVE AND 12" BELOW THE SERVICE LINE.
4. PROVIDE A MINIMUM OF 24" OF STRAIGHT COPPER AT SERVICE ENTRANCE INSIDE OF BUILDING TO ALLOW FOR INSTALLATION OF HWD METER AND VALVES.
5. INSTALL EXPANSION TANK ON COLD WATER LINE, SIZED PROPERLY FOR WATER PRESSURE, HOT WATER TEMPERATURE AND VOLUME.



DETAIL W-1
*TYPICAL SERVICE METER
 INSTALLATION*
 HANOVER WATER DEPARTMENT
 REV: 0614 BY: PEK SCALE: NTS